NOTIFICATION.

No. L.D. 2387—Legis. 5-51-112, dated Bangalore, 20th March 1952.

Ordered that Notification No. S.R.O. 363, dated 12th February 1952, 364, dated 21st February 1952 and 365, dated 23rd February 1952 of the Ministry of Works, Production and Supply amending the Indian Boiler Regulations, 1950, published in the *Gazette of India*, Part II, Section 1, dated the 1st March 1952, be republished in the *Mysore Gazette*, for general information.

By Order of His Highness the Maharaja,

N. R. JAYA RAO,
Legal Remembrancer and
Secretary to Government,
Law Department.

GOVERNMENT OF INDIA.

MINISTRY OF WORKS, PRODUCTION AND SUPPLY.

CENTRAL BOILERS BOARD.

New Delhi, the 12th February 1952.

S.R.O. 363.—In exercise of the powers conferred by section 28 of the Indian Boilers Act, 1923 (V of 1923), the Central Boilers Board hereby directs that the following amendment shall be made in the Indian Boiler Regulations, 1950, the same having been previously published as required by sub-section (1) of section 31 of the said Act, namely :—

For Regulation 527 of the said Regulations, the following regulation shall be substituted, namely :—

"524. **Procedure for Hydraulic test.** Every economiser for registration shall be hydraulically tested in the presence of an Inspector to 1½ times the working pressure. Hydraulic tests of economisers at subsequent examinations shall, when required by the Inspector, be made after the inspection. The test pressure to be applied to economisers at subsequent examinations shall be from 1¼ to 1½ times the working pressure of the economisers. During the test, all parts externally and in the flues shall be noted for leakage."

[No. M/BL-304(66).]

New Delhi, the 21st February 1952.

S.R.O. 364.—In exercise of the powers conferred by section 28 of the Indian Boilers Act, 1923 (V of 1923), the Central Boilers Board hereby directs that the following amendment shall be made in the Indian Boiler Regulations, 1950, the

854

same having been previously published as required by sub-section (1) of section 31 of the said Act, namely :—

For the table annexed to Clause (a) of Regulation 49 of the said Regulations, the following table shall be substituted, namely :—

Test pieces	Ultimate tensile strength tons/sq. in.		Minimum elongation per cent			
			On 8 inch		On 2 inch	
	Not less than	Not more than	¼ in. thick and over	Less than ¼ in. thick	¼ in. thick and over	Less than ¼ in. thick
Strips cut from tubes and tested in their curved condition.	25	33	19	17	25	23
Test lengths taken from finished tubes (ends of tubes to be plugged for grips).	25	33	23	21	...	...

[No. M/BL-304(71).]

New Delhi, the 23rd February 1952.

S.R.O. 365.—In exercise of the powers conferred by section 28 of the Indian Boilers Act, 1923 (V of 1923), the Central Boilers Board hereby directs that the following amendment shall be made in the Indian Boiler Regulations, 1950, the same having been previously published as required by sub-section (1) of section 31 of the said Act, namely :—

For clause (a) of regulation 123 of the said Regulations the following clause shall be substituted, namely :—

"(a) The furnaces of vertical boilers may be constructed in one or more lengthwise sections, each section being rolled from one plate to a full circle. In such cases, the component sections may be jointed circumferentially by electrically butt-welding or riveting. Where welded, they shall be stress relieved."

[No. M/BL-304(58).]

N. P. DUBE,
Secy., Central Boilers Board.